

LAUNCH OPERATIONS AND SUPPORT CONTRACT (LO&SC)

TECHNICAL REPORT STUDY/SERVICES MONTHLY METER READINGS (CDRL A008)

Contract Number: F04684-98-C-0014
CDRL Item Number: A008
Date Submitted: 3 August 2004





P.O. Box 5297, Bldg 861
 Vandenberg AFB CA 93437-0297
 (805) 605-1359
 FAX: (805) 734-3582

30 CES/CERF
 Bldg. 11432
 Vandenberg AFB. CA 93437

August 1, 2004

Attention: Mr. Mike Hart

Reference: Contract No. F04684-98-C-0014

Subject: LO&SC Meter Reading Requirements

1. The following are Meters read by LO&SC contractor statement of work paragraph 1.7.1, CDRL A008.

<u>Meter Location</u>	<u>Facility Meter</u>	<u>Natural Gas</u>	<u>Readings</u>	<u>Multiplier</u>	<u>TOTAL</u>
7000		BTU	950,135		950,135
7011		BTU	146		146
7050		BTU	546,704		546,704
8337		BTU	1,810		1,810
SLC-3 METER 1		BTU	999,940	* 100	99,994,000
SLC-3 METER 2		BTU	4,812,641.00		
SLC-4		BTU	39,389.00		39,389
525		BTU	39,661		39,661
719		BTU	436,662	100	43,666,200
1559		BTU	0		0
8401	#4218	BTU	4,267	* 100	426,700
8401	#7647	BTU	31,374		31,374
8510	#3061	BTU	301,588	100	30,158,800
8510	#3899	BTU	71,170		71,170

NOTE: SLC-3 (METER 1) AND BLDG. 8401 (METER 4218) HAVE MULTIPLIERS WHICH WERE NOT TAKEN INTO ACCOUNT IN THE PAST. THEY ARE NOW BEING INCLUDED IN OUR READINGS.

<u>Meter Location</u>	<u>Facility Metered</u>	<u>Electrical</u>	<u>Readings</u>	<u>Multiplier</u>	<u>TOTAL</u>
185	175	KWH	1,391	640	890,240
185	178	KWH	8,585	640	5,494,400
398		KWH	5,091	1000	5,091,000
1559	1560	KWH	0.00		
935		MWH	4,691.62		
23235	VTS ET METER	KWH	0		
23235	VTS EN METER	KWH	0		
727	M Line	KWH	CES takes	8000	
727	K Line	KWH	CES takes	8000	
75	64	KWH	16,313	1200	19,575,600
441	442	KWH	114,934,543		
500	501	KWH	59,303,788		
510	510	KWH	no meter		
907	906	MWH	12,093.60		
1280	1280	KWH	438,940		
21200	21203	MWH	6,299.97		
475		KWH	3,275	64	209,600
SLC-3		KWH	CES takes		
1639		KWH	9,360.00		
1937		MWH	1,933.81		

<u>Meter Location</u>	<u>Facility Meter</u>	<u>Water</u>	<u>Readings</u>	<u>Multiplier</u>	<u>TOTAL</u>
730			38		38

2. If you have any questions please call Merl Powell at 5-3929.

Merl Powell
Chief, Stationary Engineer