

LAUNCH OPERATIONS AND SUPPORT CONTRACT (LO&SC)

TECHNICAL REPORT STUDY/SERVICES MONTHLY METER READINGS (CDRL A008)

Contract Number: F04684-98-C-0014
CDRL Item Number: A008
Date Submitted: 5 October 2004





P.O. Box 5297, Bldg 861
 Vandenberg AFB CA 93437-0297
 (805) 605-1359
 FAX: (805) 734-3582

30 CES/CERF
 Bldg. 11432
 Vandenberg AFB. CA 93437

OCTOBER 1, 2004

Attention: Mr. Mike Hart

Reference: Contract No. F04684-98-C-0014

Subject: LO&SC Meter Reading Requirements

1. The following are Meters read by LO&SC contractor statement of work paragraph 1.7.1, CDRL A008.

<u>Meter Location</u>	<u>Facility Meter</u>	<u>Natural Gas</u>	<u>Readings</u>	<u>Multiplier</u>	<u>TOTAL</u>
7000		BTU	1,050,370		1,050,370
7011		BTU	1,491		1,491
7050		BTU	550,033		550,033
8337		BTU	2,083		2,083
SLC-3 METER 1		BTU	999,940	* 100	99,994,000
SLC-3 METER 2		BTU	4,835,547.00		
SLC-4		BTU	42,133.00		42,133
525		BTU	43,421		43,421
719		BTU	435,542	100	43,554,200
1559		BTU	0		0
8401	#4218	BTU	4,827	* 100	482,700
8401	#7647	BTU	32,421		32,421
8510	#3061	BTU	317,527	100	31,752,700
8510	#3899	BTU	71,232		71,232

NOTE: SLC-3 (METER 1) AND BLDG. 8401 (METER 4218) HAVE MULTIPLIERS WHICH WERE NOT TAKEN INTO ACCOUNT IN THE PAST. THEY ARE NOW BEING INCLUDED IN OUR READINGS.

<u>Meter Location</u>	<u>Facility Metered</u>	<u>Electrical</u>	<u>Readings</u>	<u>Multiplier</u>	<u>TOTAL</u>
185	175	KWH	1,581	640	1,011,840
185	178	KWH	8,678	640	5,553,920
398		KWH	5,110	1000	5,110,000
1559	1560	KWH	0.00		
935		MWH	4,751.05		
23235	VTS ET METER	KWH	0		
23235	VTS EN METER	KWH	0		
727	M Line	KWH	CES takes	8000	
727	K Line	KWH	CES takes	8000	
75	64	KWH	16,595	1200	19,914,000
441	442	KWH	118,841,105		
500	501	KWH	60,475,043		
510	510	KWH	no meter		
907	906	MWH	12,652.20		
1280	1280	KWH	499,319		
21200	21203	MWH	6,441.35		
475		KWH	5,401	64	345,664
SLC-3		KWH	CES takes		
1639		KWH	78,704.80		
1937		MWH	1,981.69		
<u>Meter Location</u>	<u>Facility Meter</u>	<u>Water</u>	<u>Readings</u>	<u>Multiplier</u>	<u>TOTAL</u>
730			38		38

2. If you have any questions please call Merl Powell at 5-3929.

Merl Powell
Chief, Stationary Engineer