

LAUNCH OPERATIONS AND SUPPORT CONTRACT (LO&SC)

FACILITY CORROSION CONTROL PLAN (CDRL A009)

Contract Number: F04684-98-C-0014
CDRL Item Number: A009
Date Submitted: 21 June 2004

Revision A

MCA *Engineers*
A Division of **SBAR**

* = EXT. PAINTED BY OTHER PAINT CONTRACTOR = folder # 101-B = folder # 102-B = Folder 101-F
 = Folder A = folder E = Folder Y = Folder Z

JON #	Cust.	Bldg	Location	Description	Pri.	Work Description	Mhrs	Comments
A1T030NR	2SLS	751	SLC-3E	Launch Service Building LOX and GN2 Rooms	3	STD CC	480	PIPE & CONDUIT SUPPORTS BLDG. EXT. WALLS
		754	SLC-3E	Theodolite Station	1	STD CC	80	NEEDS MAJOR SIDING REPAIR
		757	SLC-3E	Pyro Storage and Checkout Facility	3	COMP REPAINT	70	BLOCK WALLS & FACIA, DOOR
		759	SLC-3E	Security Control Point	1	STD CC	230	TURNSTILES, METAL TRIM, DOORS
80	*	760	SLC-3	Tech Supt Bldg-Annex	4	STD CC	240	METAL TRIM & DOORS
67 to 68	*	761	SLC-3	Technical Support Bldg	3	STD CC	270	SIDING NEEDS REPAIR
69 to 71	*	762	SLC-3	Technical Support Bldg	4	STD CC	100	SIDING NEEDS REPAIR & DOORS
	*	762-A	SLC-3	Technical Support Bldg	4	STD CC	100	SIDING NEEDS REPAIR
72 to 74	*	763	SLC-3E	Launch Operations Bldg	4	STD CC	100	TURNSTILES BOXES
66	*	764	SLC-3	Technical Support Bldg	1	STD CC	100	ESCORT REQUIRED, PIPING, A/C UNIT
64	*	765	SLC-3	TSB/Main Bldg	4	NA	100	TOUCH-UP
76 to 79	*	766	SLC-3E	Payload Support Bldg	1	COMP REPAINT	600	POWER LINES CHECK WITH SAFETY
75	*	768	SLC-3W	Entry Control Point	4	STD CC	140	GATE AND TRACKS NEED R & R
6 to 8		776	SLC-3E	Storage Bldg	1	COMP REPAINT	180	NEEDS SIDING & ROOF REPAIR
14 to 21		777	SLC-3	Power Substation	1	STD CC	300	STRUCTURE /RAIN GUTTER R & R
9 to 13		778	SLC-3	Utility Building	1	STD CC	160	CHILLER & SUPPORTS
65	*	789	SLC-3	Fitness Center	4	STD CC	80	TOUCH-UP
54	*	783	RSCH	Communication Shack	1	COMP REPAINT	60	ROOF REQUIRES REPAIR (GALV)
55 to 58	*	790	SLC-3	Support Bldg	1	COMP REPAINT	420	NEEDS SIDING REPAIR (GALV)
			SLC-3E	Mobile Service Tower	2	STD CC	7,400	MST. DOORS & STRUCTURE NORTH SIDE PRI #1 (ONGOING)
			SLC-3E	Umbilical Tower	2	STD CC	4,000	CONDUITBOXES, PIPING & SUPPORTS ADDED (ONGOING)
			SLC-3E	Oxidizer Storage Area	3	STD CC	450	TOUCH-UP
			SLC-3E	Pipe Trenches	3	STD CC	1000	PIPING SUPPORTS & GRATING
			SLC-3E	Fuel Storage Area	3	STD CC	1000	TOUCH-UP
			SLC-3E	Mech Supt Bldg		STD CC	50	TOUCH-UP
			SLC-3E	Switchhouse		STD CC	50	TOUCH-UP
19 to 33		960	So VAFB	SRM Storage Bldg	1	STD CC	450	NEEDS SIDING REPAIR
								SLC-3E A1T030NR TOTAL EST. MHRS 16,850
A2D09000 2 to 7	2SLS	330	So VAFB	Solid Rocket Motor (SRM) Storage Bldg	4	STD CC	500	TOUCH - UP

* = EXT. PAINTED BY OTHER PAINT CONTRACTOR ■ = folder # 101-B ■ = folder # 102-B ■ = Folder 101-F
 ■ = Folder A ■ = folder E ■ = Folder Y ■ = Folder Z

JON #	Cust.	Bldg	Location	Description	Pri.	Work Description	Mhrs	Comments
1		331	So VAFB	Hazardous Storage Facility	1	STD CC	120	COMPLETE REPAINT
8 to 31		398	So VAFB	Solid Rocket Motor Unit (SRMU) Storage Bldg	1	COMP REPAINT	20,000	EXTERIOR MAJOR WORK NEEDED SIDING REPAIR & ABRASIVE BLASTING
A2D09000 58,59,60,61, 62,63,	2SLS	713	SLC-4E	Fuel /trir pad	1	STD CC	800	STRUCTURE & SUPPORTS
		714	SLC-4E	Fuel Incinerator Pad	2	STD CC	400	PIPE, SUPPORTS & STAIRS INCINERATOR
		715	SLC-4E	Fan House 4 & 5	3	STD CC	160	COMP PAINT
64,65,66,67, 68,69,70		715	SLC-4E	Launch Service Bldg (TSB)	1	STD CC	1200	CHILLERS, DOORS, PIPE, SUPPORTS & STAIRS
120 to 134 41 TO 104		715	SLC-4E	Mobile Service Tower (MST) Loading Dock, Tracks,, Blast Shields	1	STD CC	28,000	BRUSH & ROLL DUE TO OPS & H-VAC (ONGOING)
109 TO 119		715	SLC-4E	Umbilical Tower (UT)	1	STD CC	6,000	BRUSH & ROLL DUE TO OPS & H-VAC (ONGOING)
1,2,3,4,		716	SLC-4E	Fuel Holding Area (FHA)	4	STD CC	400	TOUCH - UP
52,53,54,55, 56,57,		717	SLC-4E	Payload Fairing Air Conditioning Bldg	1	COMP REPAINT	1000	PIPE SUPPORTS, VENTS GN2 AREA
			SLC-4	POV Lot Light Poles	4	STD CC	120	TOUCH-UP BOLTS
89,90,91,92, 93,94,95, 99, 100,101,102, 103,104,105 106,107,108		719	SLC-4E	MST Air Conditioning Bldg	3	COMP REPAINT	900	A/C UNITS & STRUCTURE EXT. BLDG. TRANSFORMERS NEED REPAIR SPRAY ONLY
		720	SLC-4E	Live End Storage Area	1	STD CC	200	DOORS & VENTS & FIRE HYDRANTS & POLES
73,74,75,76,7 7,38,79,80,81 82,83		722	SLC-4E	Oxydizer Holding Area (OHA)	1	STD CC	2400	LARGE ROOF NEEDS REPAIR STRUTURE & PIPE RACK SUPPORTS
47,48,49,50,		T-723	SLC-4	Modular Support Bldg	1	STD CC	240	METAL DOORS, CHILLERS (HANDRAILS NEED REPAIR)
34,35,36,		723	SLC-4	Fitness Center	3	STD CC	100	TOUCH-UP
		723	SLC-4	ELEC PWR STN BLDG	1	STD CC	120	Barbwire fence needs some R & R in areas
		724	SLC-4	Exterior Lighting	4	STD CC	300	TOUCH-UP
51		725	SLC-4	Technical Support Bldg (TSB2)	4	STD CC	40	TOUCH-UP
96,97,98, 32,33,		726	SLC-4E	Oxydizer Scrubber Pad	1	COMP RE PAINT	550	
		727	SVAFB	Electrical Switch House	2		120	DOORS & VENTS

* = EXT. PAINTED BY OTHER PAINT CONTRACTOR ...= folder # 101-B ...=folder # 102-B ...=Folder101-F
 ...= Folder A ...= folder E ...=Folder Y ...= Folder Z

		728	SLC-4	Security Fences	3	STD CC	100	HARDWARE ON EGREES GATES
37,38,39,40		729	SLC-4	TSS UPS Bldg	1	STD CC	100	TOUCH-UP DOORS & PRI #1 CHILLERS
43,44,45,46,		730	SLC-4E	Launch Operations Bldg (LOB)	1	STD CC	400	SIDING NEEDS REPAIR EXT. SUPPORTS, PLATES,HANDRAIL
41,42		730	SLC-4E	LOB Fan House	4	NA	60	TOUCH-UP
29,30,31		731	SLC-4E	Admin Office	1	STD CC	1100	P/WASH & TOUCH UP SIDING , REPAINT ALL TRIM
			SLC-4E	Camera Towers (5)	1	STD CC	700	
JON #	Cust.	Bldg	Location	Description	Pri.	Work Description	Mhrs	Comments
A1T050NR 84,85,86,87 88	2SLS		SLC-4E	Outside Light Poles	1	COMP REPAINT	600	PAD DECK 150 FT. LIGHT POLES NEED TO CHECK GRADING
								4E A2D09000 TOTAL EST. MHRS 59,730
A1T050NR 26 TO 35 21 to 25	2SLS	733	SLC-4W	Fuel Holding Area (FHA)	1	COMP REPAINT	2300	PIPE RACK SUPPORTS & STRUCTURE
5 to 12		734	SLC-4W	Payload AC Bldg	1	COMP REPAINT	480	BLOCK WALLS & STRUCTURE,SUPPORTS
		736	SLC-4W	Oxydizer Pad	1	COMP REPAINT	2300	PIPE RACK SUPPORTS & STRUCTURE
		737	SLC-4W	Pad Support Building	2	STD CC	60	DOORS ONLY
36 TO 38 13 to 20		738	SLC-4W	Fan House	3	STD CC	120	
1 to 12		738	SLC-4W	Launch Service Bldg (LSB)	1	STD CC	700	DOORS,SUPPORTS, VENTS
		738	SLC-4W	Mobile Service Tower (MST)	1	STD CC	14,000	BRUSH & ROLL DUE TO OPS & H-VAC (ONGOING)
		738	SLC-4W	MST Tracks	1	STD CC	700	
13 to 22		738	SLC-4W	Umbilical Tower (UT)	1	STD CC	7,300	BRUSH & ROLL DUE TO OPS & H-VAC / STRUCTURAL REPAIR REQD
105 39 TO 40		739	SLC-4W	Theodolite Bldg	3	STD CC	100	DOORS & RAILS
102 103		741	SLC-4W	Vehicle Support Bldg	2	STD CC	160	DOORS,HANDRAILS, TOUCH-UP BLDG.
		742	SLC-4	Site Entry Control Bldg (SEB)	3	STD CC	100	TOUCH-UP
		742	SLC-4	SEB Turnstiles & CECO Booths	3	STD CC	160	NEW TURNSTILES
		745	SLC-4	AUTO SWITCHING CEN	3	STD CC	35	Door is Buckled Needs R & R
106 TO 109		746	SLC-4	Pad Entry Control Bldg	1	COMP REPAINT	150	NEEDS METAL FASCIA & CONDUIT REPAIR
23 to 30			SLC-4W	Boiler Bldg	1	STD CC	240	CHILLER NEEDS COMP. PAINT
			SLC-4W	Camera Towers	1	STD CC	560	Decking, Grading,Conduit, Need R&R
			SLC-4W	LN2 Storage Area	1	COMP REPAINT	680	COMP. REPAINT

* = EXT. PAINTED BY OTHER PAINT CONTRACTOR = folder # 101-B = folder # 102-B = Folder 101-F
 = Folder A = folder E = Folder Y = Folder Z

92 to 100		1559	No VAFB	Vehicle Checkout Bldg	1	STD CC	700	ALL EXT. METAL, GEN. SHELL, A/C UINTS,
101 to 105		1559	No VAFB	A/C Units & Structure	1	STD CC	500	TOUCH UP EXT.
29	*	1860	No VAFB	Segment Transfer/RGLS	1	STD CC	160	ROOF OVER TRANSFORMER, A/C UINT, TRANSFORMERS
27,28,31,32, 33		1862	No VAFB	Segment Transfer/RGLS	4	STD CC	160	MAN DOORS, ROLL UP DOORS
30		1863	No VAFB	Segment Transfer/RGLS	2	STD CC	1,500	TOWERS, ELEC. BOXES & SUPPORTS
18 to 26		1894	No VAFB	RGLS/SRMU Igloo	2	STD CC	1,500	TOWERS, ELEC. BOXES & SUPPORTS
1 to 4		8337	No VAFB	Payload Fairing Processing Facility	3	STD CC	500	TOUCH UP / FACILITY EXT.
5 TO 16	*	8401	No VAFB	Vehicle Assembly Bldg	3	STD CC	500	TOUCH-UP / FACILITY EXT.
JON #	Cust.	Blsq	Location	Description	Pri.	Work Description	Mhrs	Comments
A1T050NR	2SLS	8510	No VAFB	Generator Cover	4	STD CC	20	TOUCH UP
110				Generator Structure East Side of Bldg.	3	STD CC	60	TOUCH UP
115 to 117				Generator Structure East Side of Bldg.	3	STD CC	60	TOUCH UP
118	*	8510	No VAFB	Remote Launch Control Center (RLCC)	4	STD CC	120	EXTERIOR TOUCH UP
106 to 109		8510	No VAFB	Chillers & Stands	3	STD CC	80	TOUCH UP
	*	8510	No VAFB	Doors & Jams	4	STD CC	40	TOUCH UP
114		8510	No VAFB	Ground Plates	4	STD CC	30	TOUCH UP
113		8510	No VAFB	Handrails	4	STD CC	20	TOUCH UP
111		8510	No VAFB	Security Gates	3	STD CC	70	TOUCH UP
112,118,119,		8510	No VAFB	Hydrants & Light Poles	4	STD CC	20	TOUCH UP
								SLC-4W A1T050NR TOTAL EST. MHRS 29,490
GWD01000	30CES	63	Oak Mt	Elec Pwr Sta House		STD CC		REMOVED
140*								
138 ,139	30CES *	64	Oak Mt	Generator Bldg	4	SPOT CORR	80	
134 to 137	30CES *	66	Oak Mt	Water Tank	4	STD CC	100	PIPING NEEDS INSPECTION
141	30CES *	67	Oak Mt	Pump House	4	STD CC	60	ALL BUMPPER POLES
142	30RANS *	68	Oak Mt	Guard Shack	4	STD CC	60	TOUCH UP
128*	30RANS *	70	Oak Mt	Supply/Storage Bldg	4	STD CC	60	TOUCH UP
122 to 127*	30RANS *	75	Oak Mt	TRS Operations Bldg	4	STD CC	140	TOUCH UP
129 to 133*	30RANS *	81	Oak Mt	35 ft Antenna	3	STD CC	240	HANDRAILS ,STAIR METAL ONLY
*120,121	30RANS *	86	Oak Mt	30 ft Antenna	3	STD CC	80	TOUCH UP
1,2	30RANS *	175	Tranq Pk	Metric Radar (FPS 16-2)	4	STD CC	100	TOUCH UP

* = EXT. PAINTED BY OTHER PAINT CONTRACTOR █ = folder # 101-B █ = folder # 102-B █ = Folder101-F

█ = Folder A █ = folder E █ = Folder Y █ = Folder Z

3	30RANS *	178	Trang Pk	Metric Radar (FPS 16-1)	4	STD CC	100	TOUCH UP
4	30RANS *	181	Trang Pk	Optical Tracking (LA-24)	4	STD CC	100	TOUCH UP
5,6,7,	30CES *	185	Trang Pk	Generator/Substation	4	STD CC	85	TOUCH UP
8	30RANS *	188	Trang Pk	Bore Sight Tower	4	STD CC	60	BLDG. TRIM
48 to 50	30RANS	441	So VAFB	Freq Monitoring Station	4	STD CC	80	Fire pipe valve R & R
47	30CES	442	So VAFB	FMS Generator Bldg	4	STD CC	60	TOUCH UP
51 to 53	30RANS	475	So VAFB	Operational Comm Ctr	4	STD CC	240	TOUCH UP
10	30RANS *	500	So VAFB	Air Route Survel Radar	4	STD CC	120	A/C UINTS
9	30CES *	501	So VAFB	ARSR Generator Bldg	4	STD CC	60	TOUCH UP
12 to 16	30RANS *	510	So VAFB	Command Transmitter-3	4	STD CC	100	A/C UNITS, DOORS, TOUCH UP
17 to 18	30CES *	511	So VAFB	CT-3 Generator Bldg	4	STD CC	60	TOUCH UP
32 TO 35	30CES	520	So VAFB	SRB Processing & Storage Bldg	4	SPOT CORR	120	TOUCH-UP EXT.
JON #	Cust.	Bldg	Location	Description	Pri.	Work Description	Mhrs	Comments
GWD01000	30CES	522	So VAFB	SRB Storage Pit	4	STD CC	40	TOUCH-UP
36								
37 TO 48	30CES	525	So VAFB	South Vnbg. Power Plant	1	STD CC	1,700	AIR VENTS ON ROOF BEYOND C.C
35 to 36	30CES	702	So VAFB	Water Tank	4	STD CC	100	TANK NEEDS ROOF REPAIR
59 to 61	30CES *	780	SLC-3	Pump House	3	STD CC	120	TOUCH-UP BLDG.
62 to 63	30CES	781	SLC-3	Water Tank	3	STD CC	140	VALVE PITS
			SLC-3E	Power Substation			0	
	30RANS	890	So VAFB	Bore Site Tower	2	COMP REPAINT	400	TOWER
41 to 43	30RANS	906	So VAFB	TPQ-18 Gen Bldg	4	STD CC	70	TOUCH-UP
40 to 46	30RANS	907	So VAFB	TPQ-18 Metric Radar	4	STD CC	70	TOUCH-UP
44 to 45	30RANS	908	So VAFB	TPQ-18 Pump House	4	STD CC	70	TOUCH-UP
39	30RANS	929	So VAFB	Command Transmitter-2	4	STD CC	30	TOUCH-UP
37 to 38	30CES	935	So VAFB	CT-2 Generator Bldg	3	STD CC	100	TOUCH-UP
5 TO 7	30 RANS	1280	No VAFB	High Frequency Site	2	STD CC	160	
89	30 CES *	1638	No VAFB	HAIR UPS Bldg	4	STD CC	60	
90,91	30 RANS *	1639	No VAFB	HAIR Metric Radar	3	STD CC	300	
83 to 88	*	1640	No VAFB	HAIR Generator Bldg	1	STD CC	160	SKIN NEEDS R & R
34	30 RANS *	1937	No VAFB	HF Receiver Site	4	STD CC	100	
*	30 RANS	7000	No VAFB	Test Op Central Ctr	3	STD CC	1000	
*	30 CES	7005	No VAFB	Facility	4	STD CC	80	A/C UNIT, VENTS & PIPING
*	30 RANS	7007	No VAFB	UPS Bldg	4	STD CC	80	A/C UNIT, VENTS & PIPING
*	30 RANS	7011	No VAFB	VAFB Ntwk Control Center	3	STD CC	600	A/C UNIT, VENTS & PIPING
	30 RANS	7050	No VAFB	Data Transfer Division Bldg	4	STD CC	160	TOUCH-UP
39	30 RANS *	21101	No VAFB	TPQ-39, Radar Block Bldg	4	STD CC	40	

* = EXT. PAINTED BY OTHER PAINT CONTRACTOR ■ = folder # 101-B ■ = folder # 102-B ■ = Folder 101-F

■ = Folder A ■ = folder E ■ = Folder Y ■ = Folder Z

35	30 RANS *	21200	No VAFB	Command Transmitter-1	4	STD CC	60	A/C & CHILLER SUPPORTS
36	30CES *	21203	No VAFB	CT-1 Generator Bldg	4	STD CC	60	TOUCH UP
	30CES	23260	VTS	Sewage Treatment & Disposal Plant	3	STD CC		UPON PRGM OFFICE APPROVAL
								GWD01000 TOTAL EST. MHRS 9,390
EOS331RN	NASA	810	So VAFB	Tracking Antenna		STD CC		NOT ON APPENDIX LIST
		811	So VAFB	Tracking Station Bldg		STD CC		NOT ON APPENDIX LIST
		832	So VAFB	450' Antenna Tower		STD CC		NOT ON APPENDIX LIST
		836	So VAFB	Telemetry, S/C Chkout & Storage Facility		STD CC		NOT ON APPENDIX LIST
		840	So VAFB	Mission Director Center		STD CC		UPON PRGM OFFICE APPROVAL
		1601	No VAFB	Guardshack				UPON PRGM OFFICE APPROVAL
	*	1603	No VAFB	Fire Suppression		STD CC		UPON PRGM OFFICE APPROVAL
JON #	Cust.	Bldg	Location	Description	Pri.	Work Description		Comments
EOS331RN	NASA *	1604	No VAFB	Generator Bldg		STD CC		UPON PRGM OFFICE APPROVAL
	*	1605	No VAFB	Monitoring & Control Center		STD CC		UPON PRGM OFFICE APPROVAL
	*	1610	No VAFB	Hazardous Propellent Processing Facility		STD CC		UPON PRGM OFFICE APPROVAL
	*	1615	No VAFB	Horizontal Processing Facility		STD CC		UPON PRGM OFFICE APPROVAL
	*	1616	No VAFB	Theodolite Bldg		STD CC		UPON PRGM OFFICE APPROVAL
	*	1618	No VAFB	Electrical Modification Facility		STD CC		UPON PRGM OFFICE APPROVAL
	*	1619	SLC-2	Pad Support Bldg		STD CC		UPON PRGM OFFICE APPROVAL
	*	1620	SLC-2	Calibration Lab		STD CC		UPON PRGM OFFICE APPROVAL
	*	1620C	SLC-2	Storage Building		STD CC		UPON PRGM OFFICE APPROVAL
	*	1620B	SLC-2	Storage Building		STD CC		UPON PRGM OFFICE APPROVAL
	*	1620D	SLC-2	Storage Building		STD CC		UPON PRGM OFFICE APPROVAL
	*	1621	SLC-2	Admin Building		STD CC		UPON PRGM OFFICE APPROVAL
	*	1622	SLC-2	Blockhouse		STD CC		UPON PRGM OFFICE APPROVAL
53 ,54 ,69		1622	SLC-2	Cable Trench Grates & Plates	1	STD CC	3,400	NEED PLATES REMOVED & REINSTALLED
47 to 48		1622	SLC-2	Camera Stands & Handrails	2	STD CC	240	
49		1622	SLC-2	2 Deluge Valve Pit	2	STD	160	
50 to 52		1622	SLC-2	Light Poles	1	STD CC	450	CHECK GRADING ON TOP
3 to 42		1622	SLC-2	Mobile Service Tower	1	STD CC	11,000	BRUSH & ROLL (NO SRAYING)
43 to 44		1622	SLC-2	Facility Umbilical Tower	1	STD CC	4,500	BRUSH & ROLL (NO SRAYING)

* = EXT. PAINTED BY OTHER PAINT CONTRACTOR = folder # 101-B = folder # 102-B = Folder101-F
 = Folder A = folder E = Folder Y = Folder Z

45 to 46		1623	SLC-2	Launch Mount	3	STD CC	160	
74, 75		1623A	SLC-2	Booster Fuel Area Valve Skid, Lines, Supports	3	STD CC	160	TOUCH-UP
66 TO 68		1623A	SLC-2	N2 Tank Farm	2	COMP REPAINT	480	POWER WASH
		1623A	SLC-2	Pad Electrical Bldg		STD CC		UPON PRGM OFFICE APPROVAL
56 to 62,73		1623B	SLC-2	Payload Air Conditioning Bldg		STD CC		UPON PRGM OFFICE APPROVAL
76 to 78		1623C	SLC-2	LOX Area	1	STD CC	240	SKIN & LOWER STRUCTURE R&R
63 to 65		1623C	SLC-2	GN2O4 Transfer Area	3	STD CC	160	
71		1623C	SLC-2	2nd Stage Fuel Area	3	STD CC	120	
70		1623C	SLC-2	2nd Stage Shelter	3	STD CC	80	
79 81,82		1625	SLC-2	Deluge Piping	3	COMP REPAINT	60	
80		1625	SLC-2	Proof Load Facility		STD CC		UPON PRGM OFFICE APPROVAL
JON #	Cust.	Bldg	Location	Description	Pri.	Work Description	Mhrs	Comments
EOS331RN	NASA *	1625	SLC-2	Sound Suppression System Pumphouse		STD CC		UPON PRGM OFFICE APPROVAL
	*	1626	SLC-2	Site Entry Control Bldg		STD CC		UPON PRGM OFFICE APPROVAL
		1627	SLC-2	Sound Suppression System Water Tank	3	COMP REPAINT	400	BRUSH & ROLL DUE PARKING LOT
		1633	SLC-2	Camera Towers	1	COMP REPAINT	160	MAJOR SIDING REPAIR
								EOS331RN TOTAL EST. MHRS 23,230
A2S126RR	DET-9	1972	LF03	Environmental Shelter (Except AGE)	3	STD CC	180	TOUCH UP
24		1972	LF03	Shelter Track & Bumper	3	STD CC	80	TOUCH UP
		1972	LF03	Light Standards & Supports	3	STD CC	30	TOUCH UP
		1972	LF03	All Outside Ferrous Metal (Except C-Band & CTLI Towers)	3	STD CC	140	TOUCH UP
22,23		1980	LF06	Environmental Shelter (Except AGE)	3	STD CC	180	TOUCH UP
		1980	LF06	Shelter Track & Bumper	3	STD CC	80	TOUCH UP
		1980	LF06	Light Standards & Supports	3	STD CC	30	TOUCH UP
		1980	LF06	All Outside Ferrous Metal (Except C-Band & CTLI Towers)	3	STD CC	140	TOUCH UP
								A2S126RR TOTAL EST. MHRS 700

* = EXT. PAINTED BY OTHER PAINT CONTRACTOR ■ = folder # 101-B ■ = folder # 102-B ■ = Folder101-F
■ = Folder A ■ = folder E ■ = Folder Y ■ = Folder Z

GWD02000	22 SOPS	23200	VTS	Ext Security Lighting		SPOT CORR		NOT ON APPENDIX LIST
	*	23201	VTS	60 FT Ant UPS Bldg		SPOT CORR		NOT ON APPENDIX LIST
	*	23202	VTS	DOMSAT Ant		SPOT CORR		NOT ON APPENDIX LIST
		23205	VTS	Propane Tank		SPOT CORR		NOT ON APPENDIX LIST
	*	23209	VTS	Pump House		SPOT CORR		NOT ON APPENDIX LIST
	*	23210	VTS	Storage Bldg		SPOT CORR		NOT ON APPENDIX LIST
		23211	VTS	150 K Gallon Water Tank		SPOT CORR		NOT ON APPENDIX LIST
	*	23215	VTS	Power Plant		SPOT CORR		NOT ON APPENDIX LIST
	*	23216	VTS	DAP UPS Bldg		SPOT CORR		NOT ON APPENDIX LIST
	*	23217	VTS	Storage Bldg		SPOT CORR		NOT ON APPENDIX LIST
	*	23220	VTS	Security Entry Control Bldg		SPOT CORR		NOT ON APPENDIX LIST
		23223	VTS	Security Fence		SPOT CORR		NOT ON APPENDIX LIST
JON #	Cust.	Bldg	Location	Description	Pri.	Work Description	Mhrs	Comments
GWD02000	22 SOPS	23225	VTS	DAP Bldg		SPOT CORR		NOT ON APPENDIX LIST
	*	23228	VTS	Storage Bldg		SPOT CORR		NOT ON APPENDIX LIST
	*	23229	VTS	Admin Bldg		SPOT CORR		NOT ON APPENDIX LIST
	*	23233	VTS	10 Meter Ant		SPOT CORR		NOT ON APPENDIX LIST
	*	23235	VTS	46 FT Ant UPS Bldg		COMP REPAINT		NOT ON APPENDIX LIST
	*	23240	VTS	Maintenance Bldg		SPOT CORR		NOT ON APPENDIX LIST
								GWD02000 TOTAL EST. MHRS 2,200
GWD03000	30SW	75	Oak Mt	Weather Hut-65	2	SPOT CORR	40	
		88	Oak Mt	Weather Hut	2	SPOT CORR	40	
		179	Tran Pk	Weather Hut-56	4	SPOT CORR	20	
		313	Boat Hs	Weather Hut-53	4	SPOT CORR	20	
		376	SLC-6	Weather Hut-301	4	SPOT CORR	20	
		444	Arguello	Weather Hut-14	4	SPOT CORR	20	
		460	Arguello	Weather Hut-MOTR	4	SPOT CORR	20	
11		509	SVAFB	Weather Hut-55	2	SPOT CORR	40	
		644	UHF Rd	Weather Hut-	2	SPOT CORR	40	
		740	SLC-4	Weather Hut-300	4	SPOT CORR	20	
		756	SLC-3	Weather Hut-54	4	SPOT CORR	20	
		843	Site 66	Weather Hut-66	4	SPOT CORR	20	
		900	Mesa Rd	Upper Air Observatory	4	SPOT CORR	20	
		956	HSSF	Weather Hut	2	SPOT CORR	40	CAN NOT FIND
		1180	Agena TF	Weather Hut-4	4	SPOT CORR	20	
		1633	SLC-2	Weather Hut-102	4	SPOT CORR	20	
		1759	MSS	Weather Hut-5	2	SPOT CORR	40	

* = EXT. PAINTED BY OTHER PAINT CONTRACTOR = folder # 101-B = folder # 102-B = Folder101-F
 = Folder A = folder E = Folder Y = Folder Z

	*	1764	13th St	Upper Air Observatory	3	SPOT CORR	80	
		1891	Site 59	Weather Hut-59	2	SPOT CORR	40	
		1968	LF-06	Weather Hut-17	4	SPOT CORR	20	
		1983	LF-08	Weather Hut-60	2	SPOT CORR	40	
		2521	New Mex	Weather Hut-51	4	SPOT CORR	20	
		6832	13th St	Weather Hut-58	4	SPOT CORR	20	
		10709	Site 7	Weather Hut-7	4	SPOT CORR	20	
		21149	NVAFB	Weather Hut-15	4	SPOT CORR	20	
37 to 38	*	21150	NVAFB	Base Weather Station	4	SPOT CORR	40	
17		23252	VTS	Weather Hut-8	3	SPOT CORR	40	
								GWD03000 TOTAL EST. MHRS 760
								TOTAL ESTIMATED MHRS 142,350